

Professional Testing Laboratory Inc.

TEST REPORT

 DATE: 04-14-2023
 Page 1 of 1
 TEST NUMBER: 0296199

 CLIENT
 Egetaepper a/s

	ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for
TEXT AN ETHICATA CONTINUE TELA	Specific Optical Density of Smoke Generated by Solid Materials



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Colortec Wool 1500 LF
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

CONDITIONS				
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE	24 Hours at 140° F 24 Hours at 70° F an	d 50% Relative Humidity		
TESTING CONDITION	As Received	As Received		
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm	
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H ₂ O	
TEST MODE	Non-Flaming			

AVERAGE MAXIMUM DENSITY CORRECTED (Dmc) NON-FLAMING		309	
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			93
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	315.0	297.0	322.0
Time to Dm (minutes)	20.0	20.0	20.0
Clear Beam (Dc)	3.0	2.0	2.0
Corr. Max Density (Dmc)	312.0	295.0	320.0
Density at 1.5 minutes	41.0	39.0	54.0
Density at 4.0 minutes	93.0	86.0	99.0
Time to 90% Dm (minutes)	13.5	13.0	12.5
Specimen Weight (grams)	15.4	15.4	15.5

APPROVED BY:

MYLAP PAR

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products, This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

Lary asbury

706-226-3283

Fax: 706-226-6787

protest@optllink.us

TEST REPORT

DATE: 04-14-2023 Page 1 of 1 TEST NUMBER: 0296199

CLIENT	Egetaepper a/s

TEST METHOD CONDUCTED	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific
TEST METHOD CONDUCTED	Optical Density of Smoke Generated by Solid Materials



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Colortec Wool 1500 LF
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CON	IDITIONS	كالمتحريدة أكبر بمستنا أنسب	
PREDRYING OF TEST SAMPLE	24 Hours at 140° I			
CONDITIONING OF TEST SAMPLE	24 Hours at 70° F	24 Hours at 70° F and 50% Relative Humidity		
TESTING CONDITION	As Received	As Received		
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm	
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H ₂ O	
TEST MODE	Flamina			

AVERAGE MAXIMUM DENSITY CORRECT	ED (Dmc)	FLAMING	502
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			488
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	499.0	515.0	526.0
Time to Dm (minutes)	7.0	7.5	8.0
Clear Beam (Dc)	12.0	10.0	13.0
Corr. Max Density (Dmc)	487.0	505.0	513.0
Density at 1.5 minutes	154.0	163.0	181.0
Density at 4.0 minutes	474.0	489.0	501.0
Time to 90% Dm (minutes)	3.5	4.0	4,5
Specimen Weight (grams)	15.2	15.2	15.7

APPROVED BY:

NVLAP HERTON WAR AND COPE ROCKETO

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Leb Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

Dary asbury

706-226-3283

Fax: 706-226-6787

protest@optilink.us