

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
Notified body No. 1021
Cejl 480/12, Zábřdovice, 602 00 Brno, Czech Republic



issues

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1021 - CPR – 060-2/23

In compliance with Regulation No. 305/2011 (EU) of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products (Construction Products Regulation – CPR), in valid wording, Annex V, art. 1.2 b)

Textile floor coverings: Product group 4C - WO-LWT

Material: 100 % wool
Primary backing: polyester
Secondary backing: polypropylene
Technology: tufted – cut pile

Products placed on the market under the name or trade mark of:

Manufacturer: **Ege Carpets A/S**
Industrivej Nord 25, DK-7400 Herning, Denmark
ID: CVR 38454218

Manufacture location: 1) Foamtex ApS, Mads Clausens Vej 1, DK-7441 Bording, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 14041:2004/ AC:2006 Resilient, textile and laminate floor coverings – Essential characteristics

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.


Products fulfil the essential characteristic of reaction to fire: **Class C_n – s1**

The present certificate was issued on the basis of the protocol No. 1021/23/272 from 31.08.2023 issued by NB 1021 TZU Brno. Detailed description of product group is stated in Annex No. 1 of the certificate.

This certificate was first issued on September 01, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Brno, 01.09.2023



RNDr. Pavel Malčík
Managing Director

SCOPE:

Group 4 “WO-LWT” (100 % Wool / Laminated woven textile)

Group 4.1 (WO - LWT)		Tufted	Cut Pile
Class C_n - s1			
<i>Total weight</i>	1 750 – 2 650 g.m ⁻²	<i>Total thickness</i>	8,0 mm
<i>Pile weight</i>	1 100 – 2 000 g.m ⁻²	<i>Pile thickness</i>	6,0 mm
<i>Classification report</i>	VN710 222076.5 (29.08.2023)	<i>Classification</i>	EN 13501-1
<i>Samples in group</i>	Graphic Wool 1100 LWT Graphic Wool 1200 LWT Graphic Wool 1300 LWT Graphic Wool 1400 LWT Graphic Wool 1500 LWT	Graphic Wool 1600 LWT Graphic Wool 1700 LWT Graphic Wool 1800 LWT Graphic Wool 1900 LWT Graphic Wool 2000 LWT	
<i>Field of application</i>	Horizontal laid floor coverings in form of rolls . The carpet is to be mounted on subfloors of Euroclass A1 _n or A2 _n with a density of at least 1350 kg.m ⁻³ . It is declared for installation with a disperse adhesive (Ege 90 RH) or similar.		

TEST REPORTS and DOCUMENTATION:

<i>Product</i>	<i>Test report</i>	<i>Date</i> <small>*"</small>	<i>Accredited laboratory</i>	<i>Product documentation</i>
Graphic Wool 1100 LWT	VN710 222076.1	03.07.2023	OETI	
Graphic Wool 1200 LWT	VN710 222076.1	03.07.2023	OETI	
Graphic Wool 1300 LWT	VN710 222076.1	03.07.2023	OETI	
Graphic Wool 1400 LWT				
Graphic Wool 1500 LWT	VN710 222076.1	03.07.2023	OETI	
Graphic Wool 1600 LWT				
Graphic Wool 1700 LWT				
Graphic Wool 1800 LWT	VN710 222076.1	03.07.2023	OETI	
Graphic Wool 1900 LWT				
Graphic Wool 2000 LWT	VN710 222076.1	03.07.2023	OETI	

