

**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)

**Notified body No. 1021**

Cejl 480/12, Zábřdovice, 602 00 Brno, Czech Republic



issues

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**No. 1021 - CPR – 085-2/22**

In compliance with Regulation No. 305/2011 (EU) of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products (Construction Products Regulation – CPR), in valid wording, Annex V, art. 1.2 b)

### Textile floor coverings: Product group 6C - WO/PA-LWT

Material: 80% wool/ 20% polyamide  
Primary backing: polyester  
Secondary backing: laminated woven textile (polypropylene)  
Technology: tufted – cut pile

Products placed on the market under the name or trade mark of:

Manufacturer: **Ege Carpets A/S**  
Industrivej Nord 25, DK-7400 Herning, Denmark  
ID: CVR 38454218

Manufacture location: 1) Ege Carpets A/S - Industrivej Nord 25, DK-7400 Herning, Denmark  
2) Foamtex ApS, Mads Clausens Vej 1, DK-7441 Bording, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

**EN 14041:2004/ AC:2006 Resilient, textile and laminate floor coverings – Essential characteristics**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.


Products fulfil the essential characteristic **of reaction to fire: Class C<sub>fl</sub> – s1**

The present certificate was issued on the basis of the protocol No. 1021/16/033/K7/2 from 13.03.2023 issued by NB 1021 TZÚ Brno. Detailed description of product group is stated in Annex No. 1 of the certificate.

This certificate was first issued on March 13, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Brno, 13.03.2023



RNDr. Pavel Malčík  
Managing Director

**SCOPE:****Group 6C - WO/PA-LWT (80 % Wool/ 20 % Polyamide / Laminated woven textile)**

<b>Group 6.1 (WO/PA-LWT)</b>		Tufted	Cut Pile
<b>Class C<sub>n</sub> – s1</b>			
<i>Total weight</i>	1 550 - 2 350 g.m <sup>-2</sup>	<i>Total thickness</i>	8 mm
<i>Pile weight</i>	1 100 – 2 000 g.m <sup>-2</sup>	<i>Pile thickness</i>	6 mm
<i>Classification report</i>	VN710 204210.4 (09.03.2023)	<i>Classification</i>	EN 13501-1
<i>Products in group</i>	<b>Graphic 80/20 1100 LWT</b> <b>Graphic 80/20 1300 LWT</b> <b>Graphic 80/20 1500 LWT</b>	<b>Graphic 80/20 1800 LWT</b> <b>Graphic 80/20 2000 LWT</b>	
<i>Field of application</i>	Horizontal laid floor coverings in form of <b>rolls</b> . The carpet is to be mounted on subfloors of Euroclass A1 <sub>n</sub> or A2 <sub>n</sub> with a density of at least 1350 kg.m <sup>-3</sup> . It is declared for installation with a disperse adhesive (Ege 90 RH) or similar.		

**TEST REPORTS and DOCUMENTATION:**

<i>Product</i>	<i>Test report</i>	<i>Date</i>	<i>Accredited laboratory</i>	<i>Product documentation</i>
<b>Graphic 80/20 1100 LWT</b>	VN710 204210.1	29.6.2022	OETI	24.08.2022
	VN710 212648.1	13.12.2022		
<b>Graphic 80/20 1300 LWT</b>				
<b>Graphic 80/20 1500 LWT</b>				
<b>Graphic 80/20 1800 LWT</b>				
<b>Graphic 80/20 2000 LWT</b>	VN710 204210.1		OETI	24.08.2022

